

**Mandatory Public Notification Language
Notice of Drinking Water Treatment Technique Violation(s)**

CITY OF COOLIDGE (PWS 1470001) has violated the treatment technique requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. During JUNE and JULY 2024 sufficient levels of chlorine residual were not met in more than five percent (5%) of monthly samples.

What is being done? The following actions are being taken to address this issue: **The City of Coolidge has been flushing fire hydrants, flush valves and the stand pipe to discharge any water with low chlorine residuals. The DLQOR for the 4th QTR did not have any low chlorine residuals for the reporting period.**

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: Water Operator: Cliff NeSmith or Mayor: Tonia Bruckner

Area Code + phone number: Cliff (903) 875-9657.

Date Posted / Delivered on: Jan 10, 2025